



New Enterprise Stone & Lime Co., Inc.

3724 Crescent Court West ♦ Whitehall, Pennsylvania 18052 ♦ www.nesl.com
Office: 610-866-0932

LETTER OF TRANSMITTAL

To: The Borough of Kutztown
50 Kohler Road
Kutztown PA 19530
Attn: Mr. Troy Smith – Water Plant Manager

Date: April 10, 2017

RE: Quarterly Water Monitoring Reports – NESL Kutztown Quarry

We are sending you the following results per Agreement:

| DATE | MW 2 (ug/l) | MW 5 (ug/l) | MW 6 (ug/l) | MW 8 (ug/l) | MW 7 (ug/l) | MW 9 (ug/l) | MW 10 (ug/l) | WEAVER (ug/l) | SUMP (ug/l) | DISCHARGE (ug/l) |
|--|----------------|----------------|----------------|----------------|----------------|----------------|-----------------|------------------|----------------|---------------------|
| 5.0 ug/l (PCE) is health standard limit, 2.50 ug/l (PCE) per NESL / Kutztown Boro agreement | | | | | | | | | | |
| 1st Quarter 2017 | | | | | | | | | | |
| 03/30/17 | 0.93 | ND | ND | ND | ND | 0.97 | ND | ND | 1.00 | 0.95 (1 wk.) |
| 02/28/17 | 0.86 | ND | ND | ND | ND | 1.00 | ND | ND | 1.10 | 1.10 (1 wk.) |
| 01/26/17 | 1.00 | ND | 0.67 | ND | ND | 1.00 | ND | ND | 0.80 | No discharge |
| 4th Quarter 2016 | | | | | | | | | | |
| 12/13/16 | 0.98 | ND | 0.64 | 0.56 | ND | 1.00 | ND | ND | 0.88 | No discharge |
| 11/08/16 | 1.20 | 0.59 | 0.73 | ND | ND | 1.40 | ND | ND | 1.20 | No discharge |
| 10/11/16 | 1.20 | ND | 0.54 | ND | ND | 1.30 | ND | ND | 0.84 | No discharge |

The data represented here is the analytical results from a certified water laboratory. The constituent is listed as Tetrachloroethene tested under EPA Method 524.2. ND represents non-detected.

William R. Taft
Geo-Environmental Manager
New Enterprise Stone & Lime Co., Inc. dba Eastern Industries, Inc.

cc: Mr. Mike Clark – VP Production Services