



New Enterprise Stone & Lime Co., Inc.

3724 Crescent Court West • Whitehall, Pennsylvania 18052 • www.nesl.com
Office: 610-866-0932

LETTER OF TRANSMITTAL

To: The Borough of Kutztown
50 Kohler Road
Kutztown PA 19530
Attn: Mr. Troy Smith – Water Plant Manager

Date: January 21, 2019

RE: Quarterly Water Monitoring Reports – NESL Kutztown Quarry

We are sending you the following results per Agreement for Quarterly sampling:

DATE	MW 2 (ug/l)	MW 5 (ug/l)	MW 6a (ug/l)	MW 8 (ug/l)	MW 7 (ug/l)	MW 9 (ug/l)	MW 10 (ug/l)	WEAVER (ug/l)	PIPE (ug/l)	DISCHARGE (ug/l)
5.0 ug/l (PCE) is health standard limit, 2.50 ug/l (PCE) per NESL / Kutztown Boro agreement										
4 th Quarter 2018										
12/20/18									1.70	1.30
12/10/18									1.70	1.40
11/29/18									1.40	1.50
11/08/18									1.70	1.30
11/01/18	1.8	0.61	6.10	ND	ND	0.57	ND	ND		
10/30/18									2.50	2.00
10/10/18									2.92	1.70
3 rd Quarter 2018										
09/27/18										1.77
09/12/18	2.40	ND	ND	ND	ND	0.60	ND	ND	ND	1.68
08/29/18										1.72
08/09/18										1.76
07/19/18										1.40
07/10/18										2.30
2 nd Quarter 2018										
06/22/18										3.10
06/04/18										1.20
05/24/18										1.10
05/09/18										ND
04/23/18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
04/05/18									0.90	0.90
1 st Quarter 2018										
03/27/18										0.00
02/21/18	1.10	ND	ND	ND	ND	1.0	ND	ND	ND	*0.80
01/18										No Discharge

Started pumping offsite February 28, 2018.* Once sample received on 06/22, we contacted you on result and shut-off pumping to creek. We didn't receive results until mid-July. (Lab issue) Utilizing new lab for July.