



New Enterprise Stone & Lime Co., Inc.

3724 Crescent Court West ♦ Whitehall, Pennsylvania 18052 ♦ www.nesl.com
Office: 610-866-0932

LETTER OF TRANSMITTAL

To: The Borough of Kutztown
50 Kohler Road
Kutztown PA 19530
Attn: Mr. Troy Smith – Water Plant Manager

Date: February 2, 2020

RE: Quarterly Water Monitoring Reports – NESL Kutztown Quarry

We are sending you the following results per Agreement for Quarterly sampling:

DATE	MW 2 (ug/l)	MW 5 (ug/l)	MW 6a (ug/l)	MW 8 (ug/l)	MW 7 (ug/l)	MW 9 (ug/l)	MW 10 (ug/l)	WEAVER (ug/l)	PIPE (ug/l)	DISCHARGE (ug/l)
5.0 ug/l (PCE) is health standard limit, 2.50 ug/l (PCE) per NESL / Kutztown Boro agreement										

4 th Quarter 2019										
12/30/19										0.90
12/12/19										2.00
11/22/19										1.40
10/24/19										1.60
10/14/19										2.40
3 rd Quarter 2019										
09/25/19										1.00
09/10/19										2.20
08/29/19										2.40
08/08/19										1.90
07/22/19										2.40
07/09/19										2.40
2 nd Quarter 2019										
06/25/19										2.40
06/14/19										2.00
05/30/19										2.20
05/09/19										2.00
05/02/19										1.90
04/30/19										2.90
04/22/19										2.60
1 st Quarter 2019										
03/27/19										1.90
03/12/19										2.40
02/21/19										1.60
02/05/19										2.00
01/29/19										2.20
01/17/19										1.20

The data represented here is the analytical results from a certified water laboratory. The constituent is listed as Tetrachloroethene tested under EPA Method 524.2. ND represents non-detected.