



New Enterprise Stone & Lime Co., Inc.

613 2nd Street ♦ Catasauqua, Pennsylvania, 18032 ♦ www.nesl.com

To: The Borough of Kutztown
 50 Kohler Road
 Kutztown, PA 19530
 Attn: Mr. Troy Smith – Water Plant Manager

RE: Quarterly Water Monitoring Reports – NESL Kutztown Quarry

We are sending you the following results per Agreement for Quarterly Sampling:

DATE SAMPLE TAKEN	MW-2 (ug/l)	MW-5 (ug/l)	MW-6A (ug/l)	MW-7 (ug/l)	MW-8 (ug/l)	MW-9 (ug/l)	MW-10 (ug/l)	WEAVER (ug/l)		DISCHARGE (ug/l)
5.0 ug/l (PCE) is health standard limit; > 2.50 ug/l (PCE) per NESL/Kutztown Borough agreement										
1st Quarter 2022										
1/3/2022										1.40
1/14/2022										<0.5
1/31/2022										2.7*
2/8/2022										1.10
2/24/2022										1.80
3/16/2022										2.8*
3/22/2022										2.00
3/29/2022	<0.5	<0.5	7.60	<0.5	<0.5	0.9	<0.5	<0.5		
3/30/2022										2.8*
2nd Quarter 2022										
4/7/2022										2.4
4/14/2022										1.6
4/22/2022										2
5/18/2022										1.6
5/26/2022	<0.5	<0.5	5.0	<0.5	<0.5	0.7	<0.5	<0.5		
5/31/2022										2.2
6/13/2022										2.1
6/29/2022										1.1
6/30/2022			5.6				<0.5			
3rd Quarter 2022										
7/13/2022										1.80
7/26/2022			7.1				<0.5			1.20
8/11/2022										2.20
8/30/2022			4.3				<0.5			1.70
9/16/2022										1.40
9/20/2022	<0.5	<0.5	6.60	0.8	0.5	0.7	<0.5	<0.5		
4th Quarter 2022										
10/11/2022										1.80
10/31/2022			6.8				<0.5			
11/23/2022	3.6	0.6	6.2	0.6	0.6	1	<0.5	<0.5		
12/12/2022			<0.5				<0.5			
12/19/2022										0.6
12/30/2022										1

The data represented here is the analytical results from a certified water laboratory. The constituent is listed as Tetrachloroethene tested under EPA Method 524.2.

ND or <0.5 represents non-detected.

Sincerely,

Stephanie Stewart
 Geo-Environmental Specialist
 New Enterprise Stone & Lime Co., Inc